

WATER OPERATIONS Treatment Operations & Maintenance Strategy Treatment Operations & Maintenance Strategy Governance Minimum Training Requirements – Restricted Operations	Ref: TOMS-SW-GOV-00000002 Version: A Date: Dec-19
--	---

[Minimum Training Requirements – as agreed with the Water Quality Governance Steering Group - Dec 2019](#)

TOMS-SW-GOV-00000002 Minimum Training Requirements – Restricted Operations

SW DOMS (Modules 1-12) (EUSR White Card)	Hygiene Code of Practice- National Water Hygiene Card (EUSR Blue Card)	Site Induction and/or Direct Supervision
<p>Any works being carried out in a Restricted Area where direct contact is possible with abstracted (incl. untreated sources of underground or surface water), partially or fully treated water or where there is a possibility that the works could impact on abstracted, partially or fully treated water to be supplied to customers.</p> <p>This also includes work or activity impacting on any surface of an operational asset (including those temporarily out of use) which will itself be in contact with potable water at any stage in its distribution to the point where it is made available to consumers.</p>	<p>Works carried out in Restricted Areas/Non-restricted Areas where there is no potential for direct contact with abstracted, partially or fully treated water, but where there is potential for the works to indirectly impact on water quality.</p>	<p>Low risk activities and/or occasional visits to site to carry out tasks where there is no potential to impact on abstracted, partially or fully treated water.</p>
<p>Typical Examples:</p> <p>Water treatment and network operations</p> <p>TWS internal inspections, cleaning, refurbishments</p> <p>Intrusive surveys</p> <p>Water Pump maintenance</p> <p>Pipe laying and repairs</p> <p>Staff carrying out valve operations etc.</p> <p>Plant/civil maintenance and repairs</p> <p>Erecting scaffold*</p>	<p>Typical Examples:</p> <p>Ground maintenance</p> <p>Pest control</p> <p>Chemical deliveries</p> <p>Non-intrusive external surveys within restricted areas</p>	<p>Typical Examples:</p> <p>Material deliveries</p> <p>Building alarm maintenance</p> <p>Fire Extinguisher checks</p> <p>Site meetings</p> <p>Non-intrusive external surveys out-with restricted areas</p> <p>Organised visits</p> <p>Road reinstatement contractors</p> <p>“Out of hours” or “emergency” plant operators (under direct supervision)</p> <p>Erecting scaffold*</p>

WATER OPERATIONS Treatment Operations & Maintenance Strategy Treatment Operations & Maintenance Strategy Governance Minimum Training Requirements – Restricted Operations	Ref: TOMS-SW-GOV-00000002 Version: A Date: Dec-19
--	---

Note: Anyone responsible for taking water samples MUST be DOMS Module 13 trained.

***Note: Erecting scaffold inside a restricted area such as a Treated Water Storage Points (TWSP) is a different level of risk from erecting scaffold alongside a building remote from any restricted areas. Therefore the task must be assessed in conjunction with the area in which it is being carried out.**

Amendment Request

Amendments to this document can be requested by contacting the TOMS Mail Box. Amendments are made in accordance with the [Management System Document Control Procedure](#) (EQS Ref: 70.02)

Document Control

This document is a CONTROLLED DOCUMENT when viewed on EQS. The document becomes UNCONTROLLED if printed or downloaded from EQS or any other source.